



CAMBRIDGE PLUMBING PTY LTD

ABN 13 063 801 909

LICENCE No 29697

Factory 1 / 2 Independence St

Moorabbin 3189

Ph. 9555 8131

Brett Marshall VBA Licence No. 29697

Email: admin@cambridgeplumbing.com.au

Gas Safety Checklist

This inspection is for gas safety purposes only and is in accordance with the requirements of the Residential Tenancies Regulations 2021 and the Residential Tenancies (Rooming House Standards) Regulations 2012

CMS-2012 – 901/101 Tram Rd

Gasfitter contact details

Safety check completed by:	Cambridge Plumbing Pty Ltd	Inspection date:	12.10.21
Name:	Brett Marshall	Licence/ registration no.:	29697
Business address:	1 / 2 Independence St Moorabbin, VIC, 3189	Telephone:	9555 8131
Note: It is an offence to perform Type A gas appliance servicing work without the required qualifications (refer to the Plumbing Regulations)			

Property

Property type	<input type="checkbox"/> Rental property	<input type="checkbox"/> Rooming house
Property address		Owner/ Rental provider/ Agent name:
901/101 Tram Rd, Doncaster		Address:
		Telephone:

Authority to proceed (Owner/Rental provider/Agent):

Print name: _____ Signed: _____

(Record observations, including burner pressures, and faults in the observations table below)

Appliance 1 (location, type, make and model): **KITCHEN MIELE - GAS COOKTOP**
Installation check

	YES	NO	N/A
Is the installation gastight in accordance with AS/NZS5601.1?	✓		
Is the appliance and its components accessible for servicing and adjustment?	✓		
Where required by AS/NZS5601.1 is an isolation valve provided at the inlet connection of the appliance?	✓		
Is the appliance and its installation electrically safe? (Note: Electrical safety is confirmed by checking the electrical supply is isolated, checking earth continuity, checking insulation resistance (where applicable) and using bonding straps if disconnecting an appliance)			✓
Is there evidence of certification? (AGA, SAI -Global, IAPMO, Global-Mark or BSI). (Record in the observations table if there is no evidence of certification).	✓		
Where applicable are gas appliances including cookers adequately restrained from tipping over?	✓		
Is the room ventilation adequate for the installed appliances? (consider installation and building date for applicable requirements)	✓		
Where visible are clearances from combustibile surfaces in accordance with the installation instructions and AS/NZS5601.1?	✓		
Where applicable is the cowl, chimney plate or flue terminal in good condition and clear of obstruction?			✓
Where applicable is the flue adequately supported and correctly installed (i.e. terminal has correct clearance distance) and sealed at roof penetration?			✓
Where applicable is the flue, or its surroundings, clear of signs of scorching or overheating?			✓
Appliance servicing (For guidance on servicing Type A gas appliances refer to AS4575):			
Where applicable is the heat exchanger in good condition (test for spillage of combustion products)			✓
Has the appliance been cleaned of dust and debris (e.g. burner, pilot, fan, filters, air intake)?			✓
Are gas supply and burner operating pressures correct? (Note: All appliances must be operating)	✓		
Is the appliance clean of dust and debris (e.g. burner, pilot, fan, filters, air intake)	✓		
Are burner flames normal? (i.e. no evidence of flame lifting, floating, yellow tipping or sooting)	✓		
Is the appliance operating correctly including safety devices such as pressure and temperature relief valves?	✓		

GAS COOKTOP – ALL COMPLIANT – NO ISSUES TO REPORT

Record observations, including burner pressures, and faults in the observations table below

Record observations, including burner pressures, and faults in the observations table below)

LP Gas cylinder and associated components (where applicable)

Are cylinders installed on a firm, level and non-combustible base, and not resting on soil?

Are LP Gas cylinders suitably restrained and have compliant clearances?

Are hoses, pigtail and fittings in good condition and not degraded or work hardened?

Are pressure regulators correctly fitted, orientated, set and complete?

Observations and identification of faults

Remedial action to be taken

Details of observations and identified faults

Note: Include reference to a Compliance Certificate number if applicable

Declaration

I, being the person responsible for the inspection of the identified gas appliances or installations in the rental property or rooming house, particulars of which are described here, having exercised reasonable skill and care when carrying out the inspection, hereby declare on the date of inspection that the information in this report, including the observations and recommendations, provides an accurate assessment of the condition of the gas appliances or installations in the rental property or rooming house taking into account the stated extent of the installation and the limitations of the inspection and testing.

I further declare that in my judgment, the said appliance(s) and corresponding installation(s) is/are:

Compliant – gas appliance or gas installation complies with the criteria for a “gas safety check” in the residential tenancies regulations

Non-compliant – no immediate risk, however the customer should be advised that remedial work is required to be carried out to bring the gas appliance or its installation up to standard.

Unsafe – gas appliance or its installation is unsafe and requires disconnection and urgent work as the safety of persons may be at risk or there may be damage to property

Signed by gasfitter:



Next gas safety check is due within 24 months. Next gas safety check due: