



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **Delta Electronics, Inc.**
39, Sec.2, Huandong Road, Shanhua Dist.
Tainan City 74144
Taiwan

Product: **Photovoltaic (PV) inverter**

Model: **RPI M30A_xxx***

*** Remark:**

The 1st "x" denote DC switch ("1" denote with switch, "0" denote without DC switch).

The 2nd "x" denote for number of MPPT.

The 3rd "x" denote optional accessories or protection components ("0" denote with SPD & Fuse, "1" denote without SPD & Fuse, "2" denote without SPD & with Fuse).

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2008 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards :

IEC 61727:2004

Photovoltaic (PV) systems – Characteristics of the utility interface

IEC 62116:2008

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: **PV150512C17-IEC61727**

Certificate number: **U15-0224**

Date of issue: **2015-06-16**

Certification body

Dieter Zitzmann



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to EN 45011 - ISO / IEC Guide 65